

[2] Paragraph 7.1.1.1, the Table

substitute

MINIMUM USABLE AMOUNTS OF EXTINGUISHING AGENTS							
Aerodrome Category	Foam Meeting Performance Level A		Foam Meeting Performance Level B		Foam Meeting Performance Level C		Complementary Agent
	Discharge rate foam solution		Discharge rate foam solution		Discharge rate foam solution		Dry chemical powder
	Water litres	Discharge rate l/m	Water litres	Discharge rate l/m	Water litres	Discharge rate l/m	DCP kg
1	350	350	230	230	160	160	45
2	1 000	800	670	550	460	360	90
3	1 800	1 300	1 200	900	820	630	135
4	3 600	2 600	2 400	1 800	1 700	1 100	135
5	8 100	4 500	5 400	3 000	3 900	2 200	180
6	11 800	6 000	7 900	4 000	5 800	2 900	225
7	18 200	7 900	12 100	5 300	8 800	3 800	225
8	27 300	10 800	18 200	7 200	12 800	5 100	450
9	36 400	13 500	24 300	9 000	17 100	6 300	450
10	48 200	16 600	32 300	11 200	22 800	7 900	450