

**[8] Paragraph 22.1.2.3**

*substitute*

22.1.2.3 Subject to paragraph 22.1.2.3A, aerodrome fire alarms must terminate at the relevant ARFFS FSCC.

22.1.2.3A An aerodrome fire alarm (the ***alarm***) may terminate other than at the relevant ARFFS FSCC but only if:

- (a) the other termination, and the relevant procedures for it, are the subject of a written agreement between the aerodrome operator and the relevant ARFFS provider; and
- (b) at the other termination, the alarm is constantly monitored, or monitored at least to the same degree, and for the same hours, as it would otherwise have been monitored at the relevant ARFFS FSCC; and
- (c) the monitoring mentioned in paragraph (b) must be carried out by an AFASP, that is, an automatic fire alarm service provider approved by an official agency of a State or Territory government; and
- (d) at the other termination, an activated alarm is immediately notified by the AFASP:
  - (i) during the hours of ARFFS operation — to a responsible individual employed by the ARFFS provider; or
  - (ii) outside the hours of ARFFS operation — to the nearest State or Territory emergency service; and
- (e) the time taken to respond to the alarm is not materially different from the time it would otherwise take had the alarm terminated at the relevant ARFFS FSCC.